

## ZESTAWIENIE GRZEJNIKÓW

Numer pomieszczenia	Numer grzejnika	Typ grzejnika	Długość grzejnika	Wysokość grzejnika	Obliczeniowa moc grzejnika
PARTER – POMIESZCZENIA					
0.01	G0.17	22-C	L=0,6m	H=0,5m	Q=937 W
0.02	G0.18	22-C	L=0,4m	H=0,5m	Q=549 W
0.03	G0.19	22-C	L=0,4m	H=0,5m	Q=454 W
0.04	G0.20	22-C	L=0,4m	H=0,5m	Q=563 W
0.05	G0.21	22-C	L=0,4m	H=0,5m	Q=648 W
0.06	G0.22	22-C	L=0,4m	H=0,5m	Q=620 W
0.07	G0.23	22-C	L=0,4m	H=0,5m	Q=360 W
0.08	G0.24	22-C	L=0,4m	H=0,5m	Q=363 W
0.09	G0.25	22-C	L=0,4m	H=0,5m	Q=200 W
0.10	G0.26	22-C	L=0,6m	H=0,5m	Q=853 W
0.11	G0.01	22-C	L=1,1m	H=0,5m	Q=1700 W
0.12	G0.02	22-C	L=0,4m	H=0,5m	Q=496 W
0.13	G0.03	22-C	L=0,4m	H=0,5m	Q=598 W
	G0.04	22-C	L=0,4m	H=0,5m	Q=598 W
	G0.05	22-C	L=0,4m	H=0,5m	Q=598 W
0.14	G0.06	22-C	L=0,4m	H=0,5m	Q=503 W
	G0.07	22-C	L=0,4m	H=0,5m	Q=503 W
0.15	G0.08	22-C	L=0,4m	H=0,5m	Q=456 W
0.16	G0.09	22-C	L=0,7m	H=0,5m	Q=1121 W
	G0.10	22-C	L=0,7m	H=0,5m	Q=1121 W
0.17	G0.11	22-C	L=0,4m	H=0,5m	Q=590 W
0.18	G0.12	22-C	L=0,6m	H=0,5m	Q=838 W
	G0.13	22-C	L=0,6m	H=0,5m	Q=838 W
	G0.14	22-C	L=0,6m	H=0,5m	Q=838 W
	G0.15	22-C	L=0,6m	H=0,5m	Q=838 W
0.19	G0.33	22-C	L=0,4m	H=0,5m	Q=475 W
	G0.34	22-C	L=0,4m	H=0,5m	Q=475 W
	G0.35	22-C	L=0,4m	H=0,5m	Q=475 W
	G0.36	22-C	L=0,4m	H=0,5m	Q=475 W
	G0.37	22-C	L=0,4m	H=0,5m	Q=475 W
	G0.38	22-C	L=0,4m	H=0,5m	Q=475 W
	G0.38	22-C	L=0,4m	H=0,5m	Q=475 W
0.20	G0.28	22-C	L=0,4m	H=0,5m	Q=461 W
0.21	G0.27	22-C	L=0,4m	H=0,5m	Q=461 W
0.22	G0.46	22-C	L=0,6m	H=0,5m	Q=871 W
	G0.47	22-C	L=0,6m	H=0,5m	Q=871 W
	G0.48	22-C	L=0,6m	H=0,5m	Q=871 W
0.23	G0.50	22-C	L=0,5m	H=0,5m	Q=773 W
	G0.51	22-C	L=0,5m	H=0,5m	Q=773 W
0.25	G0.52	22-C	L=0,5m	H=0,5m	Q=837 W
0.26	G0.53	22-C	L=0,6m	H=0,5m	Q=912 W
0.27	G0.54	22-C	L=0,5m	H=0,5m	Q=762 W
0.28	G0.55	22-C	L=0,6m	H=0,5m	Q=962 W
0.29	G0.56	22-C	L=0,9m	H=0,9m	Q=2220 W
	G0.57	22-C	L=0,9m	H=0,9m	Q=2220 W
0.30	G0.58	22-C	L=0,6m	H=0,5m	Q=917 W
0.31	G0.59	22-C	L=0,5m	H=0,5m	Q=762 W
0.32	G0.60	22-C	L=0,6m	H=0,5m	Q=954 W
	G0.61	22-C	L=0,6m	H=0,5m	Q=954 W

PARTER – KOMUNIKACJA					
0.A	G0.30	22-C	L=0,4m	H=0,5m	Q=607 W
0.B	G0.16	22-C	L=0,4m	H=0,5m	Q=629 W
0.C	G0.31	22-C	L=0,4m	H=0,5m	Q=489 W
	G0.32	22-C	L=0,4m	H=0,5m	Q=489 W
	G0.39	22-C	L=0,4m	H=0,5m	Q=489 W
	G0.40	22-C	L=0,4m	H=0,5m	Q=489 W
	G0.41	22-C	L=0,4m	H=0,5m	Q=489 W
	G0.42	22-C	L=0,4m	H=0,5m	Q=489 W
	G0.43	22-C	L=0,4m	H=0,5m	Q=489 W
	G0.44	22-C	L=0,4m	H=0,5m	Q=489 W
	G0.45	22-C	L=0,4m	H=0,5m	Q=489 W
0.D	G0.49	22-C	L=0,8m	H=0,5m	Q=1331 W
0.E	G0.62	22-C	L=0,5m	H=0,5m	Q=707 W
	G0.63	22-C	L=0,5m	H=0,5m	Q=707 W
0.F	G0.29	22-C	L=0,4m	H=0,5m	Q=623 W
I PIĘTRO – POMIESZCZENIA					
1.01	G1.21	22-C	L=0,4m	H=0,5m	Q=530 W
1.02	G1.22	22-C	L=0,4m	H=0,5m	Q=314 W
	G1.23	22-C	L=0,4m	H=0,5m	Q=314 W
1.03	G1.24	22-C	L=0,4m	H=0,5m	Q=344 W
	G1.25	22-C	L=0,4m	H=0,5m	Q=344 W
1.04	G1.26	22-C	L=0,8m	H=0,5m	Q=1224 W
1.05	G1.27	22-C	L=1,0m	H=0,5m	Q=1546 W
1.06	G1.01	22-C	L=0,4m	H=0,5m	Q=476 W
	G1.02	22-C	L=0,4m	H=0,5m	Q=476 W
	G1.03	22-C	L=0,4m	H=0,5m	Q=476 W
1.07	G1.04	22-C	L=0,4m	H=0,5m	Q=399 W
	G1.05	22-C	L=0,4m	H=0,5m	Q=399 W
	G1.06	22-C	L=0,4m	H=0,5m	Q=399 W
1.08	G1.07	22-C	L=0,4m	H=0,5m	Q=399 W
	G1.08	22-C	L=0,4m	H=0,5m	Q=399 W
	G1.09	22-C	L=0,4m	H=0,5m	Q=399 W
1.09	G1.10	22-C	L=0,4m	H=0,5m	Q=391 W
	G1.11	22-C	L=0,4m	H=0,5m	Q=391 W
	G1.11	22-C	L=0,4m	H=0,5m	Q=391 W
1.10	G1.13	22-C	L=0,4m	H=0,5m	Q=409 W
	G1.14	22-C	L=0,4m	H=0,5m	Q=409 W
	G1.15	22-C	L=0,4m	H=0,5m	Q=409 W
1.11	G1.16	22-C	L=0,4m	H=0,5m	Q=591 W
	G1.17	22-C	L=0,4m	H=0,5m	Q=591 W
	G1.18	22-C	L=0,4m	H=0,5m	Q=591 W
1.12	G1.19	22-C	L=0,4m	H=0,5m	Q=516 W
1.13	G1.29	22-C	L=0,4m	H=0,5m	Q=457 W
	G1.30	22-C	L=0,4m	H=0,5m	Q=457 W
1.14	G1.31	22-C	L=0,4m	H=0,5m	Q=296 W
	G1.32	22-C	L=0,4m	H=0,5m	Q=296 W
	G1.33	22-C	L=0,4m	H=0,5m	Q=296 W
	G1.34	22-C	L=0,4m	H=0,5m	Q=296 W
	G1.35	22-C	L=0,4m	H=0,5m	Q=296 W
	G1.36	22-C	L=0,4m	H=0,5m	Q=296 W
1.15	G1.39	22-C	L=0,4m	H=0,5m	Q=285 W
	G1.40	22-C	L=0,4m	H=0,5m	Q=285 W

	G1.41	22-C	L=0,4m	H=0,5m	Q=285 W
	G1.42	22-C	L=0,4m	H=0,5m	Q=285 W
	G1.43	22-C	L=0,4m	H=0,5m	Q=285 W
	G1.44	22-C	L=0,4m	H=0,5m	Q=285 W
1.16	G1.48	22-C	L=0,5m	H=0,5m	Q=740 W
	G1.49	22-C	L=0,5m	H=0,5m	Q=740 W
1.17	G1.45	22-C	L=0,5m	H=0,5m	Q=790 W
	G1.46	22-C	L=0,5m	H=0,5m	Q=790 W
	G1.47	22-C	L=0,5m	H=0,5m	Q=790 W
<b>I PIĘTRO – KOMUNIKACJA</b>					
1.A	G1.37	22-C	L=0,4m	H=0,5m	Q=377 W
	G1.38	22-C	L=0,4m	H=0,5m	Q=377 W
1.B	G1.20	22-C	L=0,6m	H=0,5m	Q=867 W
	G1.28	22-C	L=0,6m	H=0,5m	Q=867 W
1.C	G1.50	22-C	L=0,5m	H=0,5m	Q=786 W
1.D	G1.51	22-C	L=1,0m	H=0,9m	Q=2655 W
	G1.52	22-C	L=1,0m	H=0,9m	Q=2655 W
<b>II PIĘTRO – POMIESZCZENIA</b>					
2.01	G2.21	22-C	L=0,4m	H=0,5m	Q=651 W
2.02	G2.22	22-C	L=0,4m	H=0,5m	Q=390 W
	G2.23	22-C	L=0,4m	H=0,5m	Q=390 W
2.03	G2.24	22-C	L=0,4m	H=0,5m	Q=432 W
	G2.25	22-C	L=0,4m	H=0,5m	Q=432 W
2.04	G2.26	22-C	L=0,8m	H=0,5m	Q=1325 W
2.05	G2.27	22-C	L=1,0m	H=0,5m	Q=1653 W
2.06	G2.01	22-C	L=0,4m	H=0,5m	Q=631 W
	G2.02	22-C	L=0,4m	H=0,5m	Q=631 W
2.07	G2.03	22-C	L=0,4m	H=0,5m	Q=520 W
	G2.04	22-C	L=0,4m	H=0,5m	Q=520 W
	G2.05	22-C	L=0,4m	H=0,5m	Q=520 W
	G2.06	22-C	L=0,4m	H=0,5m	Q=520 W
2.08	G2.07	22-C	L=0,4m	H=0,5m	Q=514 W
	G2.08	22-C	L=0,4m	H=0,5m	Q=514 W
	G2.09	22-C	L=0,4m	H=0,5m	Q=514 W
2.09	G2.10	22-C	L=0,4m	H=0,5m	Q=503 W
	G2.11	22-C	L=0,4m	H=0,5m	Q=503 W
	G2.12	22-C	L=0,4m	H=0,5m	Q=503 W
2.10	G2.13	22-C	L=0,4m	H=0,5m	Q=529 W
	G2.14	22-C	L=0,4m	H=0,5m	Q=529 W
	G2.15	22-C	L=0,4m	H=0,5m	Q=529 W
2.11	G2.16	22-C	L=0,5m	H=0,5m	Q=736 W
	G2.17	22-C	L=0,5m	H=0,5m	Q=736 W
	G2.18	22-C	L=0,5m	H=0,5m	Q=736 W
2.12	G2.19	22-C	L=0,5m	H=0,5m	Q=669 W
2.13	G2.31	22-C	L=0,4m	H=0,5m	Q=395 W
	G2.32	22-C	L=0,4m	H=0,5m	Q=395 W
	G2.33	22-C	L=0,4m	H=0,5m	Q=395 W
	G2.34	22-C	L=0,4m	H=0,5m	Q=395 W
	G2.35	22-C	L=0,4m	H=0,5m	Q=395 W
	G2.36	22-C	L=0,4m	H=0,5m	Q=395 W
2.14	G2.39	22-C	L=0,4m	H=0,5m	Q=385 W
	G2.40	22-C	L=0,4m	H=0,5m	Q=385 W
	G2.41	22-C	L=0,4m	H=0,5m	Q=385 W

	G2.42	22-C	L=0,4m	H=0,5m	Q=385 W
	G2.43	22-C	L=0,4m	H=0,5m	Q=385 W
	G2.44	22-C	L=0,4m	H=0,5m	Q=385 W
<b>II PIĘTRO – KOMUNIKACJA</b>					
2.A	G2.29	22-C	L=0,4m	H=0,5m	Q=543 W
	G2.30	22-C	L=0,4m	H=0,5m	Q=543 W
	G2.37	22-C	L=0,4m	H=0,5m	Q=543 W
	G2.38	22-C	L=0,4m	H=0,5m	Q=543 W
2.B	G2.20	22-C	L=0,8m	H=0,5m	Q=1315 W
	G2.28	22-C	L=0,8m	H=0,5m	Q=1315 W